

CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality
hereby attests that the product(s)

Low Emitting Materials

(Details as per the attached Scope of Certification)

manufactured by:

FALCON CHEMICALS LLC

AL HATTA HIBAB ROAD, JABEL ALI INDUSTRIAL AREA NO: 3, DUBAI , UAE

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

2017 AL SA'FAT DUBAI GREEN BUILDING EVALUATION SYSTEM

Accordingly, DCLD hereby authorizes the above manufacturer
to affix the DCL Product Conformity Mark on the above-mentioned product(s).



for / ENGR. AMIN AHMED AMIN
Director, Dubai Central Laboratory Department
Dubai Municipality



Certificate No: CL18020593
Valid Until: 28/05/2020



Current Issue Date: 29/05/2019
Original Issue Date: 29/05/2018

The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.
This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.

**DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME**

**SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL18020593 - Rev01**

Certificate Issued To: **FALCON CHEMICALS LLC**
HATTA AL HIBAB ROAD, JABEL ALI INDUSTRIAL
AREA No. 3, DUBAI, UAE

Applicable Standard Specification: 2017 Al Sa'fat – Dubai Green Building Evaluation
System

Applicable Specific Rules: **RD-DP21-2180-(IC)** Specific Rules for Certification of
Low Emitting Materials through Factory Assessment
as per the 2017 Al Sa'fat - Dubai Green Building
Evaluation System

S/N	Product Description	Brand Name	Product Details
1	Primers (Category 7)	ECOSTRIKE	Water based Primer for Interior/Exterior Applications: VOC (GBRS limit is max.30 g/l) Heavy metals: Cadmium and Chromium VI (GBRS limit < 500 mg/Kg), Arsenic, Mercury and Lead (GBRS limit <100 mg/Kg) Formaldehyde ≤ 10 mg/kg
		LAVADEC FR	
		LAVATEX 100	
		CEMSTRIKE	
		LAVASOL	
2	One -pack Performance	LAVACOOOL	Water Base Coating for Interior/Exterior Applications:

**DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME**

	Coatings (Category 9)	ECOTHANE COLORTOP	VOC (GBRS limit is max 140 g/l) LRV Class: Class 2 SRI Class: Class 2 White Color - See Note #3
		LAVASHIELD GP	
		LAVASHIELD SUPER	
		LAVATHANE	
		LAVAFLEX 1K	Water Base Coating for Interior/Exterior Applications: VOC (GBRS limit is max 140 g/l) LRV Class: Class 1 – White Color SRI Class: Class 1 – White Color White Color - See Note #3
		LAVADEC 600 FRC	
		LAVATEX R- 10	Water Base Coating for Interior Applications: VOC (GBRS limit is max 140 g/l)
		FLEXKOTE	
		LAVATEX 2000	
		LAVATEX RBE	
3	Two -pack Reactive Performance Coatings for specific end such as floor (Category 10)	ECOPOXY 310	Solvent Base Coating for Interior Application: VOC (GBRS limit is max 500 g/l)
		ECOPOXY 410	
		LAVAFLEX 2K	Water Base Coating for Interior / Exterior Application: VOC (GBRS limit is max 140 g/l) LRV Class: Class 1 – White Color SRI Class: Class 1 – White Color White Color - See Note #3
		ECOPOXY 610	
4	CERAMIC TILE ADHESIVE	ULTRATILE UTA	Ceramic Tile Adhesive - VOC (GBRS limit is max 65 g/l)
		ULTRATILE PD	
		ULTRATILE ST	
5	MULTI PURPOSE CONST. ADHESIVE	MARBLEX	Multi-Purpose construction Adhesive - VOC (GBRS limit is max 70 g/l)
		ULTRABOND F 440	

**DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME**

		ULTRABOND HD	
6	ARCHITECTURAL NON POROUS SEALANTS	ULTRAGROUT	Architectural Non Porous Sealants - VOC (GBRS limit is max 250 g/l)
*7	DRY WALL & PANEL ADHESIVES	BONDEX FRP	DRY WALL & PANEL ADHESIVES - VOC (GBRS limit is max 50 g/l)
		NIPPOCOL AS	
*8	WOOD FLOORING ADHESIVES	NIPPOCOL SUPER	WOOD FLOORING ADHESIVES – VOC (GBRS limit is max 100 g/l)

* Added in this scope

NOTE 1: This document forms part of the Certificate of Product Conformity bearing the same certificate number.

NOTE2: The above product shall bear the DCL Conformity Mark.

NOTE3: For colors/types not covered by the Scope, SRI and LRV shall be tested and classified based on the application of the product in the construction site to ensure that it meets the requirements of the DM-GBRS.

SRI Class 1 (≥ 78) – “Can be Used in 75 - 100% of surface to be coated – Sloped or Flat Roof”

SRI Class 2 ($29 < 78$) - “Can be Used in 75 - 100% of surface to be coated – Sloped Roof”

SRI Class 3 (< 29 or untested) – “Can be Used in 0 – 25% of surface to be coated – Sloped or Flat Roof provided the remaining area is Class 1 or 2”

LRV Class 1 (≥ 45) – “Can be used in 75-100% of surface to be /painted/coated”

LRV Class 2 (< 45 or untested) – “Can be used in 0-25% of surface to be painted/coated provided the remaining area is Class 1”.

NOTE4: This scope of certification supersedes the scope issued on 29 May 2019

Original Issue Date: 29 May 2018

Current Issue Date: 16 October 2019

Valid Until : 28 May 2020

ARIF HUSAIN AL MARZOOQI

Products Conformity Assessment Section Manager

Dubai Central Laboratory Department